

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7271-1713:104 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Advanced Fire Systems, inc., 100 South Street, Hopkinton, MA 01748
Contact: Leigh Kaiser (508) 453-9995 Fax (508) 453-9996
lekaiser@afsi.us.com

DESIGN: Model 58000-550ADV ionization smoke detector. Unit consists of resistors, capacitors, ionization chamber, diodes, and LED. This device can be set into five sensitivity modes. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Electrical: 17 to 28 VDC, 5 to 9V protocol

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as an analog ionization smoke detector for use with separately listed compatible fire alarm control units and listed Models 45681 Series detector bases (CSFM Listing No. 7300-1713:103). Refer to listee's Installation Instruction Manual for details.

NOTE: The ionization type detectors are generally more effective at detecting fast, flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen. The photoelectric type detectors are generally more effective at detecting slow, smoldering fires, which smolder for hours before bursting into flames. Sources of these fires may include cigarettes burning in couches or bedding.

XL: 7271-1394:116

07-11-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division