

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1713:108 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Advanced Fire Systems, Inc., 100 South Street, Hopkinton, MA 01748
Contact: Leigh Kaiser (508) 453-9995 Fax (508) 453-9996
lekaiser@afsi.us.com

DESIGN: Analog addressable signaling/contact monitoring modules. Model 55000-805ADV switch monitor module, Model 55000-806ADV priority switch monitor module, Model 55000-820ADV switch monitor input-output module, Model 55000-825ADV sounder control module, Model 55000-830ADV mini priority switch monitor module and Model 55000-831ADV mini switch monitor module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 17 to 28 VDC, 5 to 9 V protocol

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as monitoring modules for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XL: 7300-1394:108

09-02-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **SEPTEMBER 3, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division