

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7150-1713:0109

CATEGORY: Fire Alarm Pull Boxes

LISTEE: ADVANCED FIRE SYSTEMS, INC., 100 South Street, Hopkinton, MA 01748
Contact: Leigh Kaiser (508) 453-9995 Fax (508) 453-9996
Email: lekaiser@afsi.us.com

DESIGN: Models AX-APS2-F1 and AX-APS2-F2 manual pull stations. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 17-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and ETL label.

APPROVAL: Listed as manual pull stations for use with separately listed and compatible fire alarm control units. For indoor use only.

These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition with California amendments.

06-09-11 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **June 09, 2011**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division